



SSS Vinegar Corp.
16821 E. FM 1097 Rd
Willis, TX 77378
936-890-4900

April 28, 2020

RE: Water Filtration

To whom it may concern:

SSS Vinegar Corp. performs annual testing on the well water used in the manufacturing of vinegar at our facility. We submit samples for testing to Edge Analytical to ensure our water quality is in compliance with the Food and Drug Administration along with the International Bottle Water Association for drinking water. As preventative measures we also use RO system with <0.1ppm filters to capture any possible contaminants.

Best Regards,

A handwritten signature in black ink, appearing to read "Felix Ho".

Felix Ho
President
SSS Vinegar Corp.

Certificate of Compliance


This is to certify that

EDGE ANALYTICAL, Inc.,
An Accredited Drinking Water Laboratory,
Certification number 046, has completed the analysis of

SSS INGREDIENTS, LLC
“Willis Water”

on **April 26, 2019**, according to the IBWA “Appendix A” testing requirements for bottled drinking water. All parameters were found to be in compliance with FDA’s and IBWA’s published Standard of Quality limits for bottled drinking water.

EDGE
ANALYTICAL


Lawrence J. Henderson, PhD
Director of Laboratories

19-10142



Burlington, WA	<i>Corporate Laboratory (a)</i>	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	<i>Microbiology (b)</i>	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	<i>Microbiology/Chemistry (c)</i>	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	<i>Microbiology (d)</i>	540 SW Third Street	Corvallis, OR 97333	541.753.4946

April 26, 2019

Page 1 of 1

Mr. Felix Ho
SSS Ingredients, LLC
16821 E. FM 1097 Rd.
Willis, TX 77378

RE: 19-10142 - IBWA Annual - Willis Water

Dear Mr. Felix Ho,

Your project: IBWA Annual - Willis Water, was received on Tuesday March 19, 2019.

All samples were analyzed within the accepted holding times and were appropriately preserved and analyzed according to approved analytical protocols, unless noted in the data or QC reports. The quality control data was within laboratory acceptance limits, unless specified in the data or QC reports.

If you have questions phone us at 800 755-9295.

Respectfully

Patrick Miller, MS
QA Officer

Enclosures: Data Report



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 860.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225-360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070-503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street- Corvallis, OR 97333-541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4-Bend, OR 97701-641.639.8425

BOTTLED WATER STANDARD OF QUALITY REPORT

Client Name: **SSS Ingredients, LLC**
16821 E. FM 1097 Rd.
Willis, TX 77378

Reference Number: **19-10142**

Authorized by:

Patrick Miller
Patrick Miller, MS
QA Officer

Project: **BWA Annual - Willis Water**
Field ID: **BWA Annual**
Sample Description: **Willis Water**
Sampled By: **Willis Water**
Sample Date: **03/28/2019**

Lab Number: **20820**
Report Date: **04/26/2019**
Approved By: **anp,bj,bsp,dst,fn,hkl,hy,pdi**

Inorganic Chemicals (IOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
57-12-5	CYANIDE	ND	0.2	0.010	mg/L	OIA-1677-DW	a	
7440-36-0	ANTIMONY	ND	0.006	0.001	mg/L	200.8	a	
7440-38-2	ARSENIC	ND	0.010	0.001	mg/L	200.8	a	
7440-39-3	BARIUM	ND	1.0	0.001	mg/L	200.8	a	
7440-41-7	BERYLLIUM	ND	0.004	0.001	mg/L	200.8	a	
7440-43-9	CADMIUM	ND	0.005	0.001	mg/L	200.8	a	
7440-47-3	CHROMIUM	ND	0.05	0.005	mg/L	200.8	a	
16984-48-8	FLUORIDE	ND	2.4	0.10	mg/L	300.0	a	
7439-92-1	LEAD	ND	0.005	0.001	mg/L	200.8	a	
7439-97-6	MERCURY	ND	0.001	0.0002	mg/L	245.1	a	
7440-02-0	NICKEL	ND	0.1	0.001	mg/L	200.8	a	
14797-55-8	NITRATE-N	0.13	10	0.10	mg/L	300.0	a	
14797-65-0	NITRITE-N	ND	1.0	0.10	mg/L	300.0	a	
E-10128	TOTAL NITRATE/NITRITE	0.13	10	0.10	mg/L	300.0	a	
7782-49-2	SELENIUM	ND	0.010	0.005	mg/L	200.8	a	
7440-28-0	THALLIUM	ND	0.002	0.001	mg/L	200.8	a	
1497-73-0	PERCHLORATE	ND	0.002	0.00005	mg/L	331.0		Analyzed by UL

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, BWA or US FDA.
MRL - Method Reporting Limit.

If you have any questions concerning this report contact us at the above phone number.

FORM: cFDA.rpt



Reference Number: 19-10142

Lab Number: 20820

Report Date: 04/26/2019

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 2 of 7

Secondary Inorganic Parameters

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
7429-90-5	ALUMINUM	ND	0.2	0.010	mg/L	200.7	a	
16887-00-6	CHLORIDE	6.7	250	0.1	mg/L	300.0	a	
7440-50-8	COPPER	ND	1.0	0.005	mg/L	200.8	a	
7439-89-6	IRON	ND	0.3	0.050	mg/L	200.7	a	
7439-96-5	MANGANESE	ND	0.05	0.001	mg/L	200.8	a	
7440-22-4	SILVER	ND	0.025	0.010	mg/L	200.8	a	
14808-79-8	SULFATE	ND	250	0.2	mg/L	300.0	a	
E-10173	TOTAL DISSOLVED SOLIDS (TDS)	23	500	10	mg/L	SM2540C	a	
7440-66-6	ZINC	ND	5.0	0.005	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, BWA or US FDA.
MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Volatile Organic Chemicals (VOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
71-55-6	1,1,1- TRICHLOROETHANE	ND	30	0.4	ug/L	524.2	a	
79-00-5	1,1,2-TRICHLOROETHANE	ND	3	0.4	ug/L	524.2	a	
75-35-4	1,1- DICHLOROETHYLENE	ND	2	0.4	ug/L	524.2	a	
120-82-1	1,2,4 - TRICHLOROBENZENE	ND	9	0.4	ug/L	524.2	a	
107-06-2	1,2-DICHLOROETHANE	ND	2	0.4	ug/L	524.2	a	
78-87-5	1,2-DICHLOROPROPANE	ND	5	0.4	ug/L	524.2	a	
71-43-2	BENZENE	ND	1	0.4	ug/L	524.2	a	
56-23-5	CARBON TETRACHLORIDE	ND	5	0.4	ug/L	524.2	a	
156-59-2	CIS- 1,2- DICHLOROETHYLENE	ND	70	0.4	ug/L	524.2	a	
156-60-5	TRANS - 1,2 - DICHLOROETHYLENE	ND	100	0.4	ug/L	524.2	a	
100-41-4	ETHYLBENZENE	ND	700	0.4	ug/L	524.2	a	
75-09-2	METHYLENE CHLORIDE (DICHLOROM	ND	3	0.4	ug/L	524.2	a	
108-90-7	MONOCHLOROBENZENE	ND	50	0.4	ug/L	524.2	a	
95-50-1	O-DICHLOROBENZENE	ND	600	0.4	ug/L	524.2	a	
106-46-7	P- DICHLOROBENZENE	ND	75	0.4	ug/L	524.2	a	
100-42-5	STYRENE	ND	100	0.4	ug/L	524.2	a	
127-18-4	TETRACHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
108-88-3	TOLUENE	ND	1000	0.4	ug/L	524.2	a	
79-01-6	TRICHLOROETHYLENE	ND	1	0.4	ug/L	524.2	a	
75-01-4	VINYL CHLORIDE	ND	2	0.4	ug/L	524.2	a	
1330-20-7	XYLENES (TOTAL)	ND	1000	0.4	ug/L	524.2	a	
75-27-4	BROMODICHLOROMETHANE	ND		0.4	ug/L	524.2	a	
124-48-1	CHLORODIBROMOMETHANE	ND		0.4	ug/L	524.2	a	
67-66-3	CHLOROFORM	ND		0.4	ug/L	524.2	a	
75-25-2	BROMOFORM	ND		0.4	ug/L	524.2	a	
E-14471	TOTAL TRIHALOMETHANE	ND	10	0.4	ug/L	524.2	a	
1634-04-4	METHYL TERT-BUTYL ETHER	ND	70	0.4	ug/L	524.2	a	
91-20-3	NAPHTHALENE	ND	300	0.4	ug/L	524.2	a	
79-34-5	1,1,2-TETRACHLOROETHANE	ND	1	0.4	ug/L	524.2	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit -MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, BWA or US FDA.
 MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Synthetic Organic Chemicals (SOCs)

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
93-72-1	2,4,5-TP (SILVEX)	ND	10	0.2	ug/L	515.4	a	
94-75-7	2,4-D	ND	70	0.1	ug/L	515.4	a	
15972-60-8	ALACHLOR	ND	2	0.2	ug/L	525.2	a	
116-06-3	ALDICARB	ND	3	1	ug/L	531.2	a	
1646-88-4	ALDICARB SULFONE	ND	3	1	ug/L	531.2	a	
1646-87-3	ALDICARB SULFOXIDE	ND	4	1	ug/L	531.2	a	
1912-24-9	ATRAZINE	ND	3	0.1	ug/L	525.2	a	
1563-66-2	CARBOFURAN	ND	40	0.9	ug/L	531.2	a	
57-74-9	CHLORDANE	ND	2	0.2	ug/L	508.1	a	
75-99-0	DALAPON	ND	200	1	ug/L	515.4	a	
96-12-8	DIBROMOCHLOROPROPANE (DBCP)	ND	0.2	0.02	ug/L	504.1	a	
88-85-7	DINOSEB	ND	7	0.2	ug/L	515.4	a	
72-20-8	ENDRIN	ND	2	0.01	ug/L	525.2	a	
106-93-4	1,2-DIBROMOETHANE (EDB)	ND	0.05	0.01	ug/L	504.1	a	
76-44-8	HEPTACHLOR	ND	0.4	0.04	ug/L	525.2	a	
1024-57-3	HEPTACHLOR EPOXIDE	ND	0.2	0.02	ug/L	525.2	a	
58-89-9	LINDANE (BHC - GAMMA)	ND	0.2	0.02	ug/L	525.2	a	
72-43-5	METHOXYCHLOR	ND	40	0.1	ug/L	525.2	a	
23135-22-0	OXAMYL (VYDATE)	ND	200	2	ug/L	531.2	a	
87-86-5	PENTACHLOROPHENOL	ND	1	0.04	ug/L	515.4	a	
1918-02-1	PICLORAM	ND	500	0.1	ug/L	515.4	a	
1336-36-3	POLYCHLORINATED BIPHENYLS (PCB)	ND	0.5	0.1	ug/L	508.1	a	
122-34-9	SIMAZINE	ND	4	0.07	ug/L	525.2	a	
8001-35-2	TOXAPHENE	ND	3	1	ug/L	508.1	a	
50-32-8	BENZO(A)PYRENE	ND	0.2	0.02	ug/L	525.2	a	
103-23-1	DI(2-ETHYLHEXYL)-ADIPATE	ND	400	0.6	ug/L	525.2	a	
117-81-7	DI(2-ETHYLHEXYL)-PHTHALATE	ND	6	0.6	ug/L	525.2	a	
118-74-1	HEXACHLOROBENZENE	ND	1	0.1	ug/L	525.2	a	
77-47-4	HEXACHLOROCYCLO-PENTADIENE	ND	50	0.05	ug/L	525.2	a	
E-10253	TOTAL RECOVERABLE PHENOLICS	ND	1	1	ug/L	420.4		Analyzed by NSF

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
 MRL - Method Reporting Limit.



Reference Number: 19-10142

Lab Number: 20820

Report Date: 04/26/2019

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 5 of 7

Water Properties

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
E-11712	COLOR	ND	5	5	Color Units	SM2120 B	a	Bottle opened 4/1/19 at 1155
E-10617	TURBIDITY	ND	0.5	0.10	NTU	180.1	a	
E-10139	HYDROGEN ION (pH)	6.61	5.0-8.5		pH Units	150.1	a	Temp (C): 23.4, Bottle opened 4/2/1
E-11734	ODOR	ND	3	1	TON	SM2150	a	Temp: 38.4, Bottle opened 4/2/19 at

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, IBWA or US FDA.
MRL - Method Reporting Limit.



Reference Number: 19-10142
Lab Number: 20820
Report Date: 04/26/2019

BOTTLED WATER STANDARD OF QUALITY REPORT

Page 6 of 7

Disinfectants/DBP

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
NA	HAA(5)	ND	0.060	0.001	mg/L	552.3	a	DUPLICATE EXTRACTED HAA(5)=
15541-45-4	BROMATE	ND	0.010	0.001	mg/L	300.1	a	
10049-04-4	CHLORINE DIOXIDE	ND	0.8	0.10	mg/L	SM4500-ClO2I	a	Opr'd 3/28/19 1110
7758-19-2	CHLORITE	ND	1.00	0.020	mg/L	300.1	a	
NA	CHLOROAMINES TOTAL	ND	4.0	0.05	mg/L	SM4500-Cl G	a	Opr'd 3/28/19 1110
7782-50-5	FREE CHLORINE RESIDUAL	ND	0.1	0.05	mg/L	SM4500-Cl G	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit - MRL.
SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CBWA, BWA or US FDA.
MRL - Method Reporting Limit.

BOTTLED WATER STANDARD OF QUALITY REPORT

Radiological Contaminants

CAS ID#	COMPOUNDS	RESULT	SOQ	MRL	Units	Method	Lab	COMMENT
12587-46-1	GROSS ALPHA	ND	15		pCi/L	900.0		Analyzed by Pace
12587-47-2	GROSS BETA	ND	50		pCi/L	900.0		
13982-63-3	RADIUM226	ND			pCi/L	903.1		
15262-20-1	RADIUM228	ND			pCi/L	904.0		
7440-14-4	RADIUM 226,228 (combined)	ND	5	1	pCi/L	903.1/904.0		
7440-61-1	URANIUM	ND	0.030	0.001	mg/L	200.8	a	

Notation:

A Result of "ND" indicates that the compound was not detected above the Lab's Reporting Limit -MRL.
 SOQ - Standard of Quality, maximum permissible level of a contaminant in water established by CFWA, ISWA or US FDA.
 MRL - Method Reporting Limit.