



American Environmental Laboratories



U.S. Durum Milling
7900 Van Buren St.
St. Louis, MO 63111
Phone# (636) 586-7448

Date: 9/28/22
Contact: Nick Brammei
Job # 36925

LABORATORY REPORT

Location: Tap Water, 9:00 AM
Field: Liquid
Sample No: 6504

Sample Date: 9/22/22
Sample Received: 9/22/22
Temperature (°C): NA

	Result	Units	Detection limit
<u>Alkalinity</u>			
Alkalinity	48	mg/L	0.01
<u>Chlorine, free</u>			
Chlorine, free	0.17	mg/L	0.01
<u>Chlorine, total</u>			
Chlorine, total	1.87	mg/L	0.01
<u>Fluoride</u>			
Fluoride	0.9	mg/L	0.01
<u>Hardness, as CaCO3</u>			
Hardness, as CaCO3	152	mg/L	1
<u>pH</u>			
pH	9.13	pH	1
<u>Turbidity</u>			
Turbidity	0	NTU	0
<u>Total Coliform</u>			
Total Coliform	<1	CFU/1 mL	1
<u>E. Coli</u>			
E. Coli	<1	CFU/1 mL	1

Reviewed by:

All non-hazardous samples will be disposed of within 30 days of analytical completion.
MCL = Maximum contaminant level J = Analyte present below quantitation limits
ND = None Detected CFU = Colony Forming Units TNTC = Too Numerous to Count
* = Poor surrogate recovery due to matrix interference

3441 Morgan Ford Rd. St. Louis, MO 63116 Tel: 314-664-2800 Fax: 314-664-2442